

jim leftwich visual poems ongoing research 2016 -vol. 2









## JAN 17 2016 F O U N D

1/e

ıd

n







information, such as gambling.<sup>[2]</sup>

Gestaltanalyse des Wahns ("The onset of schizophrenia: an attempt to form an analysis of delusion"), [1] in

comed the word "Apophänie" to characterize the onset of delusional thinking in psychosis, Conrad's theories on the genesis of schizophrenia have since been partially, vet inconclusively, confirmed in psychiatric literature when tested against empirical findings.<sup>14)</sup>

Committee the control of the fact that a schizophrenic initially experiences debision as revolution. [5]

In contrast to an emphany, an aponhany (i.e., an instance of aponhenia) does not provide insight into the nature of reality or its interconnectedness but is a "process of repetitively and monotonously experiencing about the contrast of th

The market will be and a service of a service for a service of

### Related meelecters:

### "Patternicity"

In 2008, Michael Shermer coined the word "patternicity", defining it as "the tendency to find meaningful patterns in meaningless noise" [7][8]

"Agentiaty"

in the believing brain (2011), Shermer wrote that numers have the tendency to thinke patterns with meaning, intention, and agency", which he called "agenticity". [9]

"Mandomana"

in 2011, parapsychologist David Luke proposed that apparently patterned or related data) can be called opposite behaviour (attributing to chance what are apparently patterned or related data) can be called "randomania". He asserted that dream procedulation is real and that randomania is the reason who some people dismiss it. [10]

### Exermies

ESTO CONTACTOR FOR

pollination that continues indefinitely of energy. Such motion can octhe a in a frictionless medium and no often

spore, PERPETUAL MOTION have failed.

POLL tailed 1\ n.

between the computed orbit of pollinved orbit, caused by gravitational BOT celestial body. 2. PHYSICS. The dewaterredicted path, due to some cause

from its computed orbit led

### polychre

PHYSIC

Sunligh floral envelope of a flower. A

polyconic

EARTH S f a PETAL may be adaptations the may ad birds.

portion

is a cur

at that 1 leaf to a stem. 2. zoology. A north-s

verging

have a PETIOLE.

A POLY

because n.

meridi which the remains of plants or or a stonelike substance and by

polyethy ssils. The change is a chemical

CHEMI tured protec tre two common substances in-

areas

id \
Foods been infiltrated by silica, which POLYETHYLENE.

rial cell by cell. Petrified wood is

polygon llen logs, tree trunks and stumps ormed by straight line segm ells is preserved and can be idenecutive segments lie in

the s point


A POL A naturally-occurring oily liquid t amber to black and that is the

olygra

MEDIC eral d ed to record sevsimultaneously,

lows a de-

pistil by wind, breeders.



avelengths.

spaced in proe, each parallel gent to the earth rs as a straight curved lines con-

> small areas the central

tics, usually manufac-

food storage, garment

l in a number of other

moisture or chemicals


more segments have a

it has sides.



POLYCONIC PROJECTION

jim leftwich 525 10th st sw . roanoke, va 24016 usa



POLYGON

# 110pqrstuvw 17

act popular survey surv

18 Point

ABCDEFGHIJKLM. abcdefghijklmnop.


JAN 17 2016

jim leftwich 525 10th st sw roanoke, ya 24016 usa ישעי

20

















jim leftwich 525 10th st sw roanoke, va 24016 usa

JAN 20 2016










JAN 0,2 2016


















JAN 02 2016





JAN 09 2016

### R



ENGINEERING and PHYSIC electronic hat sends radio waves and receives and electronic lyzes the elected waves, or echoes. It is used to determine the direct hand distance to, an object, and uses rate to 1.0 meter.

RADAR is used by some up ations to be pud massed spicanes and other story ty.

### al metry \'rād-ē-əl 'si

The form of an aning the slave of the slave

An an DIAL SYMMETH Secut in Adentical halves axis.

#### radial velocity

ASTRONOMY. The which a star is appropriately a star is appropriately a star is appropriately a star in the star is appropriately as a star in the star

A spectroscope can be some stars.

### radian \'rād-ē-ən\ n.

MATHEMATICS. A unit of angulathe radius of a circle. It is an circle, intercepts an arc equatherefore, is an arc of a circle that circle.

2 my cerus equal 360 d RADIAN equals 1

radiant energy \'rād-ē-ənt 'en-əрнузісs. Energy that travels as electioning such energy as light, X rays and radio v

All RADIANT ENERGY travels at the speed of light.

IAN OF



JELLYFISH JELLYFISH

SYMMETRY

lay in the 1830s. Practical MHD and EGD a much shorter history, however. The him that all MHD generator was constructed in 38 by B. Karlovitz and D. Halász. These are unsuccessful, however, hecause neither of ionized gases nor the need for very high device first la the II experit the proj were sufficiently understood. By 1959, techno progressed sufficiently so that 10 kilowatts of ele er were generated with an MHD device rch and development continue Extens at Britain, Japan, Poland, the So Germ and th

Early accepts to construct a practical high-valk generates are reported in the U.S. in 1932, and in 1935, targe scale work on EGD generation of elform fossil fuel dates from the late 1960s, with degree ment work begun in the United States.

ment work begun in the United States.

The magnetoh drodynamic interaction finds put it application today in flowmeters accelerators, pumps a generators. Electromagnetic flowmeters, in use for solve decades, do not interfere with fluid flow and have too parts. They are used to measure liquid metal to the liquid metal of the

esistant, and with the state of the discount of the state of the state

MAN ETOHYDROD NAMIC POWER SENERATION

The in a important application for magnetohydred panies is poor generation. In large public-utility plants that burn fossil the large function of the foliation of the consequence of the foliation of the foliati

In the control operations, the working stud (gas) is eventually exhausted to the atmosphere in cle ed-cycle systems, the shud is reused. Toponing means that the gases therated by burning the first coal, oil, as are first passed trough an MHD generator and then on to a conventional cast generator.

ean generator.

Cross licycle nuclear of d Man systems are possible. A generator, the moderature by the nuclear reactor, rack be passed instantional and then the high the steam of the first losi heat) the respectively.

for reheating.

Power-generating systems. In a power-generating system, the work hausted to the atmosphere must be the constraint of the system of the constraint of the const

The quantity of power amount of fluid dependent of the control of the control of the combustion power yield. Consterial such as popower yields to accept

As the gas expands a the who fact and power is extracted, the gas cools and its electrical conductivity falls rapidly. At about 3,630° F (2,000° C), the MBD power generation process ceases to be economically attractive, and the simple open-cycle system thus has a low efficiency. Since the exhausted gas is still hot in comparison with normal power-plant working fluids, the efficiency of the simple open-cycle system can be supported with the simple open-cycle system can be supported by the simple open-cycle syst

jim leftwich 525 10th st sw 525 10th st sw panoke, va 24016 usa

by recovering the energy remaining in the gas stream with conventional methods.

Open cycle with heat recovery. Heat energy recovered from the MHD duct exhaust gas is wifed in two ways. First, it heats the h. h-pressure air fee to the combustion chamber. Second, the remaining heat is used to produce steam in a conventional boiler and power is generated in the conventional way.

the hear of when the sondenses on illected. Once is, precipitator feulate matter kestack. About ering the heat cal power. The m plant (45 to nan that of the erecent)

the closed-cycle of the closed-cycle of the within the closed cycle of the within the closed cycle of the cyc

by convent and steam plant standards.

Closed-cycle upand metal systems are also being developed. These are a promise better the higher thermal afficiency of gas-os le symp systems and the advantage of higher conductivity obtained by using standard as the working fluid. Liquid metals have measured to gleetrical conductivity than seeded gast, at all the system conductivity than seeded gast, at all the system conductivity than seeded gast, at all the system of t

Many liquid-ment cycles have been proposed in or space power and central power station enlication in these, the liquid metal is heated in a nut occur of the flow is vapourned and the vapourned to a high velocity in a nearly, the vapour mixes with a accelerates the liquid flow when the vapour and liquid are separated, the liquid enters the accelerator where part as kinetic energy is converted to electricity. Liquid-

accelerates the liquid flow when the vapour and liquid are separated, the liquid enters the are generator where part as kinetic energy is converted to electricity. Liquid-out systems are less efficient than gas systems.

HID generator geometries. For liquid most MHD systems, the linear duct with a single electrode on each side shown in Figure 46 is adeignate. In gaseous systems attached for bulk power generation, however, a more replicated electrode geometries frequired because of the friend than the motion of the electrons that carry the flow in the motion of the electrons that carry the flow is to the magnetic field, produces an additional carry that the motion of the electrons that carry the flow is to the magnetic field, produces an additional carry that the motion of the electrons that carry the flow is the magnetic field, produces an additional carry that the carry is the motion of the generator. To recent life the produce of the generator of the carry that the carry is the produce of the p

When the table is the content of the


diagonally cross-connecting electrodes.

Other duck designs or geometries has the proposed to counteract the Hall effect. One is the dest generator (Figure 44D), in which the gas flow ratically outward be-

The Hal

eeding uid with potassium










JAN 07 2016











JAN 22 2016

jim leftwich 525 10th st sw


























jim leftwich 525 10th st sw roanoke, va 24016 usa













JAN 24. 2016

jim leftwich 525 10th st sw roanoke, va 24016 usa


JAN 24 2016


jim leftwich 525 10th st sw oanoke, va 24016 usa















































jim leftwich





iim laftuich







jim leftwich 525 10th st sw 24216 Gsa








jim leftwich 525 10th st sw









jim leftwich 525 10th st sw


























jim leftwich 525 10th st sw










.. . . . . . . . . . . . . .


















JAN 24 2016 jim leftwich 525 10th st sw roanoke, va 24016 usa



JAN 24 2016

Jim leftwich 525 10th st sw roanoke, va 24016 usa



jim leftwich 525 10th st sw JAN 2 4 2016 anoke, va 24016 usa



jim leftwich 525 10th st sw JAN 2 4 2016 banoke, va 24016 usa



JAN 24 2016

Jim leftwich 525 10th st sw roanoke, va 24016 usa




JAN 24 2016 525 10th st sw




JAN 24 2016


jim leftwich 525 10th st sw roanoke, va 24016 usa
























name and owner	location	type	power		start-up	)	525 roanoke	
			plant kw (*) net	reactor kw (†)	ar Storela		Joanoke	
Shippingport Atomic Power		pressurized water	60,000	231,000	1957			
Station (AEC and Duquesne Light Company) Dresden Nuclear Power Station	Morris	boiling water	208,000	700,000	1959	Grand Co		
(Commonwealth Edison Company) Yankee Nuclear Power Station	Wille.	ter	161,000	540,000	1960	bids bids		
(Yankee Atomic Electric Company) Indian Point Unit No. 1	Mindian Police	water	255,000	585,000	1962	2000	. 9.1	
(Consolidated Folson Co. of New York (1847)————————————————————————————————————	Balleti, Neb	i odijan praphite	75,000	240,000	1962	12	W 53	
Sheldon States to and Consumers Pa Fower District) Big Rock Nucle at lower Plan	or in the state of	ater	47,800	157,000	1962	brill it	o somes o stores relate trong superb	
(Consumers Full ex Comply) Elk River Reacto (Consumer)	Elk River, Min	E SHILL STORY	20,000	58,200	1962		a pietdo of	
Rural Cooperation Association)	Kahladi-Main		15,000	60,000	1960		VV	
West Germany (Rhine- Power Company, RWE) Belgium (Center for the Study of Nuclear Energy, CEN)	Marital .	water	11,500	43,000	1962			

leftwich Oth st sw va 24016 usa

plant with 60,000 kilowatts of electrical po with steam to be sold to an electric-power company. technology was derived largely from experience with the submarine thermal reactor.

The concept of a boiling-water reactor was derived from experiments at the Argonne National Laboratory with a small reactor that had been allowed to boil the water surrounding the core on a continuous basis, thus suggesting the possibility of direct coupling to a steam turbine instead of using hot pressurized water from the reactor to produce steam in a boiler separate from the reactor. The experiment had shown that if the control rods were abruptly removed, thus causing a sudden power expansion, the boiling water became steam so rapidly that the moderating effect of the water was lost and the chain reaction came to a stop long before the fuel elements were damaged.

The homogeneous reactor was to be based upon ea experience at Oak Ridge. It would be slightly larger, was intended to serve as a prototype for a still larger

The sodium-graphite reactor was intended to co the well-known graphite technology as the moderator sodium cooling to achieve higher temperatures for efficient power production, without the inconver the high pressures associated with water cooling.

Finally, the potential advantages of a fast-breeder were well recognized. With the success of the experimental breeder reactor (EBR/-I), it was decid the Argonne National Laboratory should build a version (the EBR-II), also to be in Idaho at the N Reactor Testing Station. It would be scaled up to 60,000 kilowatts of heat with an electrical product of about 15,000 kilowatts. It would be loaded first uranium-235 and later with plutonium in order to er it to produce larger amounts of plutonium in the nium blanket.

By the end of the decade, each of these five experimenta reactors was operating and another had been added. A small reactor moderated with organic material had been tried because of its potential for producing fairly high steam temperatures at relatively low pressures. A major disadvantage, however, was the low heat-transfer properties of the organic material and its tendency to decompose and polymerize (combine two or more small molecules

into large ones). Except for the homogeneous-reactor concept, each of the experimental reactors led to the design and construction of industrial prototypes or demonstration reactors. Some of these plants were large enough to produce a significant amount of power, but there was still no proof that the

costs could be made competitive with power plants burning fossil fuels.

The European Atômic Energy Community. Prompted largely by a growing shortage of coal and oil, the six Common Market countries of Europe in March 1957 ratified the establishment of the European Atomic Energy Community (Euratom). Earlier, representatives from West Germany, France, and Italy had visited the United States and had discussed plans for a nuclear power program in Europe. Their report, "A Target for Euratom," noted the growing dependence of Europe on energy imports and the crisis that the threatened closing of the Suez Canal posed to obtaining oil from the Middle East. With rising the and rising demand for electric power, they about the advent of nuclear power as a ope could become less dependent on oposed that Euratom set a target of intalled nuclear power capacity

the conditions for nuclear ere more favourable than d indeed that European oving ground from which ment could benefit.

ized, partly because of the the discovery of new oil beginnings of a nucleardual-purpose graphited-reactor approach. Italy nts from both the United m and was the first to prosubstantial size to be built Euratom and the United ver, fell far short of what ed. The Euratom proposal was by utility companies, and the nd availability of nuclear fuel, ear-liability insurance, together discouraged the switch from

er Euratom's founding, two firm Euratom , projects, and a third underway, provided altogether about 700,000 kilowatts of capacity. Obviously Eurato the earlier goal was not to be achieved, and there had been only a beginning in the development of an international market for nuclear-power equipment. During the same period, Japan, with its dependence on fuel imports, recognized the potential advantages of nuclear power and began to explore the possibility of purchasing both nuclear

ing of Euratom




Figure 31: A smoothed version of the load curve together with a load duration curve, indicating the neach day that a particular load is exceeded.

Reprinted from Principles of Electric Utility Engineering by C.A. F M.I.T. Press, Cambridge, Massachusetts. Copyright 1955 by M.I.T.

For most economical operation the base load portion should be supplied by the power stations the operating costs of which are lowest; for example, by run-of-river-flowtype hydroelectric stations, by the most efficient thermal power stations in the system, and, increasingly, by nuclear power stations. The peak load portion should be supplied by power stations the construction costs of which are low. Peak load is relatively high in kilowatts but relatively short in duration, so that total kilowatt-hours are not great. Peak load may be supplied by pumped-hydro stations, old thermal power stations, and gas-turbin

Pumped hydro requires no pumping the water to the st




Figure 32: Typical load duration curves for a one-year period, showing how base load can be substantially increased (right) demand to operate a by using power during pumped storage system

can be used for pumping disting the level of base load (see Figure 32, right). The puddle load is then supplied by older type thermal stations, to accommodate starting and stopping of turbines one or wice a day, thermal stations are designed especially for a buildle-part use. Effective are designed especially fo system planning requires estimates of future changes in the percentages for the three types of load.

## INTERCONNECTION

To determine how much generating capacity should be built into a power system, a number of factors must considered. Foremost is the maximum peaked system. Emergency conditions (e.g., a fault in station or in transmission lines) must be conas scheduled outages for regular repair To provide the necessary reserve may peak power requirements, a certain required, sometimes expressed as 15 percent and sometimes by the total of the two large system. Each system must be considered indivicapacity of the largest generating unit is normal to 10 percent of the total system capacity.

The investment cost of generating capacity per kilo is usually lower as unit size increases, making the use of larger units economically beneficial. In a small system, however, such benefits cannot be realized. Larger systems can be assembled by interconnecting two or more smaller systems, thus enabling the use of a larger generator unit. Interconnections must be designed to give an adequate

power flow through interconnecting lines in an emergency. If help from neighbouring systems can be counted on in case of emergency, as can be realized by interconnection, reserve margins can be reduced, resulting in considerable

economic benefits.

Interconnection also has economic advantages in day-today utility systems operations. Where system load conditions would normally require the operation of a generating station with airelatively low efficiency if the system were operating dependently, interconnection can cut fuel costs by making use of more efficient generators from a neighbouring system. Another advantage of intercon-nection is the flexibility at allows in choosing sites for new generating stations; planning takes into consideration the interconnected systems as a whole rather than a single independent system. Because of these law antages, electric-power systems have grown that the connection between different and the connection and the connection between different and the connection and the connecti even interconnections between

Interconnection introduces made must be solved in system operat line power flow, for example, in to neighbouring electric power's controlled in the day-to-day apar nected system. Such power flew is normals on a contractual basis between the utility mined erned. many The complexity of systems with intercon points and at various voltages, however, erea problems, for the solution of which the analog computer has been used since the 1930s. Such computers, known as ac calculating boards, network calculators, or network analyzers, have proved to be effective tools for solving power flow problems in interconnected system operation and planning. In the late 1960s they began to nd flexiby digital computers, which have gry bility. In many instances on-line co is used for the operation of large inter

In addition to the norma lex phone and radio, a util network for telemeteri functions. Extensive In circuits, carrier teleph for carrier telephony the high-frequency waves

As a power system gro turbances increases prop m be rupturing capacity of all ciriring caincreased. A circuit breaker v One way pacity may explode when a sys to alleviate the problem is to intro reactance (a circuit component that impedes the of alternating current) into the system to reduce the fault current. Such reactance causes a voltage drop in system during normal operation, however, and so has backs. Connecting two systems with a dc linking possibility. No ac fault current flows this ing device; thus fault current is restricted

Another problem with interconnected is possibility of a large-scale blackout that a fault cambe ed section switched fault. Power systems are designed se located almost instantly and the fault a very short time, thus allow it stuble operation of the system, whatever the nature and location

design is usually on a single contingency tem operation two or more confingencies are transcously, perhaps leading to a wide-men of power. Weather disturbances may transmission lines, while an error on the part patcher, or failure of a protective apparatus circuit breakers), cannot be excluded. Thus, ead blackouts, such as that of November 1965 in northeastern United States and southeastern Canada, can occur. Much can be learned from such large-scale power failures. First, reserve capacity, to be effective in an emergency, should be a spinning reserve; that is, the equipment must be in such a state that the output capacity can be used very soon after the disturbances. The time needed to produce electricity from a thermal station

Importance of reliable communications

Potential . of largescale power outages

Factors in planning capacity of a system

jim leftwich 525 10th st sw roanoke, va 24016 usa

Figure 33 Induction motor fields and their interaction with rotor and stator conductors. © indicates that the flow of current is directed toward viewer, perpendicular to page. So current is drapted away from viewer (see text).

the same but whose phase relationship is B shows schematically a stator on wheen wound; coils 1 and 3 are so conis in the direction shown, field at the stator surface south at the lower coils. What the polarities of the fields. so that a current i<sub>2</sub> produ Figure 33A, at a given ins and  $i_2$  is zero. Under these this shown in Figure 33C. period late The current  $i_1$  is zero, and  $i_2$ mum. The resulting field condi now as shown in Figure 33D. At a third instant, advanced to a maximum, but in the negative sense, has fallen back to zero from a positive maximum. field situation is now that of Figure 33E. Finally, at  $i_1$  has again become zero and  $i_2$  has reached a negati maximum, and Figure 33F shows the resulting fields. The to travel around the periphery of north implete revolution while the c lence a revolving field olely upon the g the ed for one cycle lutions will be n in one minute the revolvi wn as the synchron in size so that it half the state e (Figure 33G), the as far for each cyc will travel current, and the speed of the revolving in 1,800 revolutions per minute for a 60-h coil arrangement of Figure 33B is said to p pole motor, since at any instant there is but and but one south pole. The arrangement of Figure 33G, on the other hand, will produce two north poles and two south poles at any instant and therefore is a four-pole stator. It is not uncommon to have as few as two or as many as 100 poles in a motor. The speed of the revolving magnetic field in revolutions p a minute in any motor is 120 f(p), in which f is the frequency  $\ln f$  hertz and p is the

In a practical motor the stator will have than indicated here, and these will be dist its periphery in equally spaced slots. I makes better use of the available space uted around arrangement an does the strated-coil arrangement desc

above, but established. Il the same—a revolving nductors is unife as shown in the upng electrical contactsduced voltages y the dashed line in Figure 33H. The the rotor and south pole of the stator will each other, and a torque will be exerted on the rotor tending to turn it in the direction of the rotating field.

If the rotor is travelling at the same speed as the revolving field, there will be no induced tage in the conductors, no current flow, and no torque. Hence, at synchronous speed the torque drops to zero. If the rotor travels faster than synchronous speed, the direction of the induced voltage and the current will be reversed, thus reversing the torque;

the motor is now serving as an induction generator.

Construction features. The rotor and stator are built up of laminations of 0.25 perce at silicon steel, re) thick. from 0.014 to 0.025 i The laminations are lating varnish to reduce the in the laminations (eddyslots are punched in

(usually th energy sou i in-The former technique more than 600 volts or about 100

that form the wound, squire solid. To make a two-phase degrees, or o s) is placed in t are brought ou onze rings on w e an electrical connecti

squirrel-cage winding ma um or copper or built up fr ded to a common end ring. To cast tack of rotor laminations is inserted in a centrifugal machine and molten aluminum or copper is introresult, after the metal solidifies, is an integrally igitudinal conductors and end rings. The oduction line enerally is used for st es under 100 horsep ar type is more co

ing is the otor, in which a n rotated etic field to general to its speed. A solid on teel will also pro inuous-winding rotor for

Polyphase induction modes connection is by far the most of stator ause most industrial power distribution three-phase. In this type of motor the revolving field is different currents whose phase relationships are 120° instead of the 90° shown in Figure 33A.

Both squirrel-cage and wound-rotor motors may be used in polyphase service; however, the latter are usually reTypes of secondary windings

ur-pole ator





jim leftwich 525 10th st sw roanoke, va 24016 usa

JAN 24 2016





jim leftwich
525 10th st sw
roanoke, va 24016 usa

JAN 2 7 2016









JAN 27 2016

jim leftwich 525 10th st sw roanoke, va 24016 usa




JAN 27 2016


jim leftwich 525 10th st sw roanoke, va 24016 usa




JAN 27 2016


jim leftwich 525 10th st sw roanoke, va 24016 usa






















## TLPress Roanoke VA USA 2021